## **U. S. Environmental Protection Agency**

## Region III - Philadelphia PA

Please Note: This information is initial notification data and may be subject to verification.

Incident Notification No. 1053598 Incident Type: FIXED Incident Date: 7/12/2013 12:00:00 PM Incident Cause: UNKNOWN

Incident Location

3464 POWER PLANT

NULL NULL

City\*: CLEVELAND

Zip: NULL State: VA

County: RUSSELL

Affected Medium

Medium: LAND Waterway: NULL

Tributary to: NULL

Additional Medium Info: CONCRETE PAD

\* Nearest City to Incident location is given. Incident may not have occurred within city borders.

Spilled Material: POLYCHLORINATED BIPHENYLS Quantity: 500 Units: PART(S) PER MILL

**Potential Response Party** 

First Name: KAREN Company: AMERICAN ELECTRIC POWER

Last Name: GILMER Type: PUBLIC UTILITY

Monday, July 23, 2018 Page 1